

## INDEX

- ACI CODE-318-19, 106, 135, 144  
ACI PRC-201.2-23, 135  
A-frame dead-end structures, 10, 252  
Air core reactors. *See* [current-limiting inductors](#)  
Air density factor ( $Q$ ), 34  
Air-insulated substations, 7, 252  
AISC. *See* [American Institute of Steel Construction](#)  
AISC 341-16, 50  
Allowable strength design (ASD), 2, 76, 103  
Alloy 6061-T6, 106  
Alloy 6063-T5, 106  
Alloy 7075-T54, 106  
*Aluminum Design Manual*, 106, 108  
American Institute of Steel Construction (AISC), 169  
Analysis: ANSI/AISC 360-22, requirements in, 93–94; approximate, 92; ASCE 10-15, requirements in, 95; ASCE 48-19, requirements in, 94; definition, 89; eigenvalue, 95–96; first-order elastic, 92; first-order inelastic, 93; recommendation for: dynamic analysis, 96–97; seismic analysis, 96–97; static analysis, 96; response spectrum, 96; second-order elastic, 92–93; of short-circuit events, 97–102; A-frames/jumper transitions, arrangements with, 100–102; dynamic time-history model, 99–100; joint fixity, 100; rigid bus analysis methods, 98–100; simplified static analysis, 99; steady-state, 95; stress criterion *vs.* deflection criterion, 89; structure model, 89–91; finite-element model, 91; frame model, 90–91; individual members and connections, 90; loads and support conditions, 91; truss model, 90  
Anchor materials, 147–149  
Anchor rod on leveling nuts design (example), 216–217  
Anchor steel, design considerations for, 153–160; anchor rods with base plate on concrete/grout, 154–155; base plate supported by anchor rods with leveling nuts, 155–160  
ANSI/AISC 360-22, 92, 93–94, 104–105  
ANSI/AWC NDS-2015, 108  
ANSI O5.1-2017, 108, 185  
Application of loads, 73  
Approximate analysis, 92  
Arresters. *See* [surge arresters](#)  
ASCE 7-22, 33–34, 44, 52  
ASCE 7 Hazard Tools website, 44–45, 52  
ASCE 10-15, 95, 104  
ASCE 48-19, 94, 104–105  
ASCE 74, 33–34  
ASCE 123-12, 106  
ASCE MOP 141, 172  
ASD. *See* [allowable strength design](#)  
Aspect ratio, 42, 266  
ASTM A123/A123M, 120  
Autotransformers, 13  
  
Ballistic walls, 195–196  
Barrier walls, 194–196; ballistic walls, 195–196; blast walls, 195–196; firewalls, 194–195; general, 194; sound walls, 195  
Base plate design, 109–113; anchor rod holes in, 112–113; anchor rod loads, determination of, 111; deflection-sensitive structures, base and flange plate design for, 113; example, 217–218; thickness, determination of, 111–112  
Biot–Savart law, 238

- Blast walls, 195–196
- Box-type structures, 10
- Bus ducts, 25
- Bus-work system, 8, 252
- Cable bus system, 8, 252
- Cable terminators, 24, 26
- CC. *See* coupling capacitor
- CCVT. *See* coupling capacitor voltage transformer
- CIGRE Brochure 105: *The Mechanical Effects of Short-Circuit Currents in Open Air Substations*, 68
- Circuit breakers, 19–20
- Circuit breaker tank, 19–20
- Circuit switcher (load interrupter switch), 18–19
- Class A structures, 82–84; deflection limits of horizontal members in, 82–83; deflection limits of vertical members in, 82–83
- Class B structures, 84; deflection limits of horizontal members in, 84; deflection limits of vertical members in, 83–84
- Class C structures, 85; deflection limits of horizontal members in, 83, 85; deflection limits of vertical members in, 84–85
- Combined footing foundation, 126
- Concrete, design considerations for, 160–162; anchor rod embedment length, 160–161; anchor spacing, 160; capacity, 160; concrete punch out from anchor rods, 161–162; edge distance, 160; localized bearing failure, 162
- Connections to foundations, 143–164
- Constructability, 137
- Construction, 175
- Construction loads, 70–71, 136
- Control enclosures, 27
- Corrosion, 132
- Coupling capacitor (CC), 15
- Coupling capacitor voltage transformer (CCVT), 15–17
- CTs. *See* current transformers
- Current-limiting inductors, 13–15
- Current transformers (CTs), 21–22
- Dead-end structures, 9, 252; A-frame, 10, 252; H-frame, 10, 252; load development for (example), 211–216; combined ice and wind, 213–214; extreme wind, 212–213; NESC district loading—heavy loading, 215–216
- Dead loads, 29
- Dead tank circuit breaker, 19–20
- Deep foundations, 127–128; drilled shafts, 127–128; pile foundations, 128
- Deflection analysis and criteria, 81–82; horizontal members, 81–85; special considerations for, 85–87; anchorage and member connection restraints, 85–86; gross *vs.* net deflections, 86–87; multiple-use structures, 85; rigid bus vertical deflection criteria, 87; rotational limitation, 85; shielding masts and other tall, slender structures, 86–87; vertical members, 82–85
- Deflection (example), 218–224; three-phase bus support stand—class “B” structure, 218–220; three-phase switch support stand, double column—class “A” structure, 222–224; three-phase switch support stand, single column—class “A” structure, 220–222
- Deflection limitations, loading criteria for, 71–72; ice with concurrent wind load for deflection calculations, 72; other considerations, 72; wind load for deflection calculations, 71–72
- Design, 103–123; aluminum structures, 106–108; allowable strength design according to IEEE 693, 108; applications to substation structures, 107; bolted connections, 107; limitation with aluminum substation structures, 107; substation alloys and tempers, 106; ultimate strength design, 108; weldments, 107; aluminum with dissimilar materials, 122–123; concrete in contact with aluminum, 123; steel in contact with aluminum, 122–123; wood in contact with aluminum, 123; base plate, 109–113; anchor rod holes in, 112–113; anchor rod loads, determination of, 111; deflection-sensitive structures, base and flange plate design for, 113; thickness, determination of, 111–112; concrete structures, 105–106; prestressed, 106; prestressed concrete

- poles, 106; reinforced, 106; galvanizing steel considerations, 120; general principles, 103; guyed substation structures, 122; magnetic fields of air core reactors, precautions regarding, 117–119; member connection design, 120–122; aluminum, welded connections in, 121; bolted connections in steel, 120; concrete structure connections, 121; steel, welded connections in, 120–121; wood structures, connections in, 122; methods, 103; painted/metallized steel considerations, 120; rigid bus, 113–117; aluminum in, 114; aluminum shapes in, 114; bolted-type fittings, 115; bus layout configuration, 113; composite, 116; copper in, 114; couplers, 115; expansion fittings, 115; fixed fittings, 115; porcelain insulators, 115–116; seismic considerations, 116–117; slip fittings, 115; system design, 116; seismic design guidelines, 108–109; structures not included in IEEE 693, 109; structures support electrical equipment qualified for IEEE 693, 109; spectral accelerations, 52; steel structures, 104–105; hollow tubular member shapes, 104–105; lattice angle structures, 104; local buckling of irregular polygonal shapes, 105; standard structural shapes other than angles, 104; vortex-induced oscillation and vibration, 119; weathering steel structures, 122; wood structures, 108; allowable strength design, 108; ultimate strength design, 108
- Design-level qualification, 63
- Direct embedded foundations, 128
- Disconnect switches, 16–18
- Distribution lines, 6
- Downdrag forces, 132
- Drilled pier foundations, 146
- Drilled shafts, 127–128
- DTHM. *See* dynamic time-history model
- Dynamic time-history model (DTHM), 99–100
- Earthquakes, 48, 74
- Eigenvalue analysis, 95–96
- Electrical clearances, 8, 252
- Electromagnetic force variation with time, 238–243
- Embedded structural shapes, 147
- Equipment operating loads, 29–30
- Equivalent lateral force (ELF) procedure, 57–59; horizontal distribution of seismic forces, 59; rigid substation structures, 59; vertical distribution of seismic forces, 59
- Excavations, 136–137
- Expansive/collapsible soils, 131–132
- Fabrication inspection, 168–169; AISC, 169; reports, 169; test assembly, 169; visual inspection, 168; of welds, 168–169
- Fabricators, 28
- Finite-element analysis, 91
- Fire barriers, 27, 194–195
- Firewall. *See* fire barriers
- First-order elastic analysis, 92
- First-order inelastic analysis, 93
- Force coefficient ( $C_f$ ), 42–44; lattice structure, 42–44
- Foundations, 125–141; anchor arrangements and general design considerations, 149–152; anchor rods with base plates on concrete or grout, 152; base plates supported by anchor rods with leveling nuts, 151–152; anchor materials, 147–149; anchor rods installed without grout beneath base plates, 147; anchors cast in place, 152–162; anchor steel, design considerations for, 153–160; concrete, design considerations for, 160–162; deformed reinforcing bars, 153; headed rods, 153; hooked rods, 153; combined footing, 126; concrete for, 135; connections to, 143–164; deep, 127–128; design considerations, 131–133; corrosion, 132; dynamic loads, 132–133; expansive/collapsible soils, 131–132; frost action, 131; seismic loads, 132–133; soil–structure interaction, 133; direct embedded, 128; drilled pier, 146; drilled shafts, 127–128; embedded structural shapes, 147; geotechnical subsurface exploration, 129–131; existing subsurface and geotechnical data, 129; general, 129; geotechnical report, 130; other considerations, 131; seismic considerations, 130;

## Foundations (cont.)

site-specific subsurface exploration, 129–131;  
 soil borings, 130; grade beams, 127;  
 helical screw anchor piles, 128;  
 loading considerations, 133–134;  
 load application, 133;  
 load combinations, 134; mat, 126;  
 overview, 125; pile, 128; post-installed  
 anchors in concrete, 162–164; design, 163;  
 installation, 163–164; types and  
 application, 162–163; shallow, 126–127;  
 special considerations, 135–141;  
 constructability, 137; construction  
 loads, 136; deflection, 137–138; grounding  
 of substation equipment and structures,  
 138–139; group effects, 136; National  
 Electrical Safety Council District Loading  
 and Foundation Design, 140–141; operational  
 loads, 135; rotation, 137–138; seismic base  
 isolation, 138–139; settlement, 137–138;  
 slopes and excavations, 136–137; uplift  
 loads, 138; spread footing, 126, 144–145

*Foundations and Earth Structures*, NAVFAC

DM 7.02, 125

Frame model, 90–91

Frost action, 131

Full-scale structural proof tests, 176

Gas-insulated substations (GISs), 7–8, 252

General cable theorem, 31–32

Geotechnical subsurface exploration,  
 129–131; existing subsurface and  
 geotechnical data, 129; general, 129;  
 geotechnical report, 130; other  
 considerations, 131; seismic  
 considerations, 130; site-specific subsurface  
 exploration, 129–131; soil borings, 130

GISs. *See* gas-insulated substations

Glaze ice, 44–48

Grade beams, 127

Group effects, 136

Gust response factors ( $G_{SRF}$  and  
 $G_{WRF}$ ), 37–42

Heavy Timber Construction (HTC), 185

Helical screw anchor piles, 128

H-frame dead-end structures, 10, 252

Horizontal members, 81–82

Ice loads with concurrent wind, 44–48;

effects of icing event on structures, 47–48;

ice thickness variation with height, 48

Ice with concurrent wind load for deflection  
 calculations, 72

IEC 60865-1: *Short-Circuit Current – Calculation  
 of Effects*, 68

IEEE 605: *IEEE Guide for Bus Design in Air  
 Insulated Substations*, 68

IEEE 693, 2, 30, 49–50, 52, 63–65, 109

IEEE 980-2013, 193

IEEE 1527-2018, 30

IEEE C37.04, 30

IEEE C37.30.1, 30

IEEE C57.19.01, 30

IEEE C57.19.100, 30

Insulators, 24–26

Joint fixity, 100

Lightning mast, 12–13

Line trap, 15–16

Live tank breaker, 19–20

Load and Resistance Factor Design (LRFD).

*See* ultimate strength design (USD)

Loads: allowable strength design (ASD)

load combinations, 76; alternate  
 design, 78; application of, 73; basic  
 loading conditions, 74; construction  
 and maintenance, 70–71; dead, 29;  
 deflection limitations, 71–72; equipment  
 operating, 29–30; factors and  
 combinations, 73–78; ice loads with  
 concurrent wind, 44–48; seismic, 48–67;  
 serviceability considerations, 78–79;  
 short-circuit (fault), 9; state and local  
 regulatory, 72; ultimate strength design  
 (USD) load combinations, 75; wind, 32–44;  
 wire tension, 30–32

Maintenance, 136, 175–176

Manual of Practice (MOP), 1–3, 6, 8, 28–30,  
 35–44, 47, 49–50, 53–55, 57, 62

Mat foundations, 126

Maximum considered earthquake  
 (MCE), 49

MCE. *See* maximum considered  
 earthquake



- Mean recurrence interval (MRI) wind speed, 37
- Metalclad switchgear. *See* unit substations
- MOP. *See* Manual of Practice
- National Electrical Safety Code  
Loads, 72, 103
- National Electrical Safety Council District Loading and Foundation Design, 140–141
- Natural Resources Conservation Service (NRCS), 129
- Negative skin friction. *See* downdrag forces
- Neutral grounding resistors, 23–24
- Ohm's law, 233
- Oil containment, 191–194; berms and dikes, 193; design considerations, 193–194; general, 191–192; oil absorbents, 193; oil retention drainage, 193; oil retention pit, 192; oil solidifiers, 193; self-extinguishing, 193; substation mat, 192; systems, 192
- Oil retention drainage, 193
- Operational loads, 135
- Owners, 28
- Pack out, 122
- PCI MNL-120 Design Handbook—Precast and Prestressed Concrete, 106
- P-delta amplification, 92
- Peak ground acceleration (PGA), 49
- Peak ground velocity (PGV), 49
- Performance-level qualification, 63
- PGA. *See* peak ground acceleration
- PGV. *See* peak ground velocity
- Phase-to-ground fault, 68
- Phase-to-phase fault, 68
- Pile foundations, 128
- Post-installed anchors in concrete, 162–164; design, 163; installation, 163–164; types and application, 162–163
- Potential transformers (PTs), 21
- Pothead. *See* cable terminators
- Power transformers, 13
- Pre-Standard for Substation Structure Design* (draft), 249–318; applicable documents, 249–251; barrier structure requirements, 301–313; construction and maintenance, 317–318; design of members, 294–301; foundations, 313–316; load cases and combinations for strength design, 252–256; loads, 256–294; purpose, 249; quality assurance and control, 316–317; scope, 249
- Prestressed concrete poles, 106
- Prestressed concrete structures, 106
- Prestressed Concrete Transmission Pole Structures: Recommended Practice for Design and Installation*, 106
- PTs. *See* potential transformers
- Quality assurance/quality control (QA/QC) programs, 167–173; aluminum structures, 170–171; fabrication, 171; inspection, 171; material, 170; structure coating, 171; welding, 170–171; concrete structures, 171–172; inspection, 172; prestressed concrete poles, 172; reinforced concrete, 171; handling and storage, 173; shipping, 172–173; steel structures, 168–170; fabrication inspection, 168–169; material, 168; structure coating, 170; welding, 168; wood structures, 172; fabrication, 172; inspection, 172; manufacturing, 172; material and treatment, 172
- Recommended Practice for the Design and Use of Wood Pole Structures for Electrical Transmission Lines*, 108
- Reinforced concrete structures, 106
- Response spectra (RS), 49
- Response spectrum analysis, 96
- Retrofit of existing substation infrastructures, 179–190; of anchorage, 183; design considerations, 187–189; environmental concerns, 185–186; asbestos in existing substations, 185–186; demolition activities, 186; renovation activities, 186; soil contamination in existing substations, 186; galvanized structures, 184–185; general, 179–180; installation, 190; methods for, 181–183; painted structures, 184; security and resilience of electrical substations, 186–187;

- Retrofit of existing substation infrastructures (cont.)
  - steel structures, considerations for, 183–184; timber structures, 185; types of structures for, 180–181; weathering structures, 185
- Rigid bus analysis methods, 98–100
- Rigid bus system, 8, 252
- Rime ice, 48
- RS. *See* response spectra
- Second-order elastic analysis, 92–93
- Seismic base isolation, 138–139
- Seismic design guidelines, 108–109;
  - structures not included in IEEE 693, 109;
  - structures support electrical equipment qualified for IEEE 693, 109
- Seismic design parameters, 245–248
- Seismic loads, 48–67; anchorage
  - design forces, 63–65; equipment to structure, 64–65; IEEE 693, 63–65; basic effect, 61–62; design response spectra, 52; importance factors for, 55; with overstrength factor, 62; purpose and scope, 49–50; seismic analysis, 55–60; dynamic analysis procedure, 60; equivalent lateral force procedure, 57–59; selection of method, 55–57; seismic deflection considerations, 63; seismic demand on other components, 65; seismic design coefficients/factors, 52–54; seismic ground motion acceleration parameters, 50–52; design spectral accelerations, 52; site-specific ground motion procedures, 51–52; vertical seismic load effect, 60–61; on wire bus, 66–67
- Self-extinguishing oil containment, 193
- Series capacitors, 22, 24
- Serviceability, 78–79
- Shallow foundations, 126–127; combined footing foundation, 126; grade beams, 127; mat foundations, 126; spread footing foundation, 126
- Shielding mast, 11–12, 252
- Short-circuit current, 233–238
- Short-circuit events analysis, 97–102;
  - A-frames/jumper transitions, arrangements with, 100–102; dynamic time-history model, 99–100; joint fixity in, 100; rigid bus analysis methods, 98–100; simplified static analysis, 99
- Short-circuit (fault) loads, 9, 67–70, 252; additional information, 70; on equipment, 70; on rigid conductors, 69–70; on strain bus, 70; to structures, 243
- Shunt capacitors, 21–23
- Shunt reactors, 13–14
- Slab foundation. *See* mat foundations
- Slack-span tension, 30
- Slopes, 136–137
- Soil–structure interaction, 49
- Solidity ratio ( $\Phi$ ), 43–44
- Sound walls, 195
- Spread footing foundations, 126, 144–145
- Square root of sum of squares (SRSS), 60
- State and local regulatory loads, 72
- Steady-state analysis, 95
- Steel lattice rack-type structure, dynamic analysis of (example), 224–231; modal properties, 229–231; overview, 224–228
- Strain bus conductor, 31
- Strain bus system, 8, 252
- Stress criterion *vs.* deflection criterion, 89
- Structure designer, 28
- Substation dead-end structures, 30
- Substations, 5–6, 252
- Sub-transmission, 6
- Suppliers, 28
- Surge arresters, 23, 25
- Switchyard/switching station, 5–6, 252
- Taps, 31
- Terminal connection loads for electrical equipment, 30
- Terminal connectors, 30
- Terrain exposure coefficient ( $K_z$ ), 34–37; effective height ( $z$ ), 37; exposure categories, 35–36
- Three-phase bus support structure, load development for (example), 199–211; combined ice and wind loads, 202–203; deflection case wind loads, 210–211; extreme wind loads, 201–202; insulator and bus fitting data, 201; rigid bus data, 200–201; seismic loads, 203–209; short-circuit loads, 209–210; structure data and geometry, 199–200

- Three-phase fault, 68  
Transformers, 27  
Transmission lines, 6–7, 252  
Truss model, 90
- Ultimate strength design (USD), 2, 75, 103  
United States Geological Survey (USGS), 48  
Unit substations, 6, 252  
Uplift loads, 138  
USD. *See* ultimate strength design  
US Geological Survey (USGS), 129  
USGS. *See* United States Geological Survey  
USGS Relative Seismic Hazard map, 50
- Vertical members, 82  
Vertical seismic load effect, 60–61  
VIO. *See* vortex-induced oscillation  
VIV. *See* vortex-induced vibrations  
Vortex-induced oscillation (VIO), 71  
Vortex-induced vibrations (VIV), 86
- Wave trap. *See* line trap
- Wind equation, 32–33  
Wind-induced oscillations, 71  
Wind loads (extreme), 32–44; air density factor ( $Q$ ), 34; application of wind forces to structures, 44; basic wind speed ( $V_{MRI}$ ), 37; for deflection calculations, 71–72; equation, 32–33; force coefficient ( $C_f$ ), 42–44; lattice structure, 42–44; gust response factors ( $G_{SRF}$  and  $G_{WRF}$ ), 37–42; mean recurrence interval wind speed, 37; terrain exposure coefficient ( $K_z$ ), 34–37; effective height ( $z$ ), 37; exposure categories, 35–36  
Wind shading/shielding, 44  
Wire tension loads, 30–32  
Worker safety, 176  
Working stress design. *See* allowable strength design (ASD)
- Yawed wind, 42
- Zero-tension condition, 105

